



**Safety instructions:**

**Installation Ex ia**

These notes are to be followed only in the case when the installed type of protection "Intrinsically safe" Ex ia is to be guaranteed:

1. Please take note of the safety instructions (XA00050R/09/a3) for "Intrinsically safe" Ex ia installation.
2. Once the system has been installed as "Intrinsically safe" Ex ia it is possible to use the system as an **EXPLOSION PROOF** transmitter with the II2G Ex db IIC T6...T4 Gb approval marking.

**Installation Ex d**

These notes are to be followed only in the case when the installed type of protection "Explosion proof" Ex d is to be guaranteed:

1. Mount the name plate with the identifier: II2G Ex db IIC T6...T4 Gb
- ⚠ Warning!  
2. Once the system has been installed as "Explosion proof" Ex d it is no longer possible to use the system as an intrinsically safe transmitter with the II1G Ex ia IIC T6...T4 Ga approval marking.
3. Please take note of the safety instructions (XA00048R/09/a3) for "Explosion proof" Ex d installation.
4. Please dispose of name plate: II1G Ex ia IIC T6...T4 Ga

Approved	Pfanzelt	Date (yyyy-mm-dd)	2011-08-04	10000004346	Dwg.rev.	A	Revision no.	-	Revision date (yyyy-mm-dd)	2017-12-13	Name	MP	Material	71376600	<b>Endress+Hauser</b>
Designed	Pfanzelt	Date (yyyy-mm-dd)	2011-08-03	TMT142	Scale	1:1	Title			Safety instructions XA01021R/09/EN/02.17		Series			
Refer to protection notice ISO 16016	Edge of working parts ISO 13715	Geometrical tolerancing ISO 2768-mH-E	Part No.		Format	A4	Objekt version		Sheet		1 of 1		Endress + Hauser Wetzler GmbH+Co. KG Nesselwang / Germany		