



GOVERNMENT OF INDIA
MINISTRY OF COMMERCE & INDUSTRY
PETROLEUM AND EXPLOSIVES SAFETY ORGANISATION (PESO)
(Formerly Department of Explosives)
CGO COMPLEX SEMINARY HILLS
NAGPUR 440006



Letter No: A/P/HQ/MH/104/3947(P354785)
Email :explosives@explosives.gov.in
Phone/Fax No.2510248/2510577
Dated : 8/4/2015

To
M/s. Endress+Hauser yamanashi Co., Ltd.,
862-1 Mitsukunugi Sakaigawa-cho,
Fuefuki-shi
Yamanashi Pref, 406-0846
Japan

15 APR 2015

Sub:Approval of equipments under Petroleum Rules, 2002

Dear Sir(s),

Please refer to letter No CCOE/EH-MKT/NMS 5XXAPPL dated 23/03/2015 from M/s. Endress hauser India Pvt. Ltd.,Mumbai on the above subject.

The following Flame Proof/Intrinsically Safe equipment(s) manufactured by you according to EN 60079-0 : 2012, EN 60079-1 : 2007, EN 60079-11 : 2012 & EN 60079-26 : 2007 standards and covered under M/s. KEMA Test reports mentioned below are approved for use in **Zone 1** of Gas Group IIB/IIC hazardous areas coming under the purview of the Petroleum Rules, 2002 administered by this Organization.

Sr.No	Description	Safety Protection	CCEs Identification Number	Test House	Test Report No.	Drawing Numbers
1	Tank Gauge Proservo NMS53., Type NMS50..... and Type NMS7-.....	Ex d {ia} IIB T6...T3 Ga/Gb / Ex d IIC T6...T3 Ga/Gb	P354785/1	M/s. KEMA	KEMA 05ATEX2071 {Issue No. 5} Dt.06/03/2015	As per test report
2	Converter, Temperature and Water Level Transmitter Prothermo Type NMT 539-B and Average Temperature Transmitter Prothermo Type NMT 532-B	Ex ia IIB T6...T2 Ga/Gb	P354785/2	M/s. KEMA	KEMA 03ATEX1448 X {Issue No. 6} Dt.11/09/2014	As per test report

This Approval is granted subject to observance of the following conditions:-

- 1). The design and construction of the equipment shall be strictly in accordance with description, condition and drawings as mentioned in the M/s. KEMA Test Reports referred to above

- 2). The equipment shall be used only with approved type of accessories and associated apparatus
- 3). The equipment shall be used only in conjunction with the approved Flame Proof/Intrinsically Safe barriers
- 4). Each equipment shall be marked either by raised lettering cast integrally or by plate attached to the main structure to indicate conspicuously
 - (a) Name of the manufacturer
 - (b) Name and number by which the equipment is identified
 - (c) Number & Date of the test Report of the M/s. KEMA applicable to the equipment
 - (d) CCEs Identification Number of this letter by which use of the apparatus is approved
- 5). A certificate to the effect that the equipment has been manufactured strictly in accordance with the drawing referred to in the M/s. KEMA/M/s. KEMA test report and is identical with the one tested and certified at M/s. KEMA shall be furnished with each equipment
- 6). The customer shall be supplied the copy of this letter, an extract of the conditions and maintenance schedule, if any recommended by M/s. KEMA in their test reports and copy of instructions booklet detailing operation and maintenance of the equipment so as to maintain its Flame Proof/Intrinsically Safe safety characteristics
- 7). The After sales service and maintenance of subject equipment shall be looked after by your representative M/s. Endress hauser India Pvt. Ltd., Raj Plaza Wing A & B 5th Floor LBS Marg, Vikhroli West, Mumbai Maharashtra (State)

This Approval also covers the permissible variation as approved under the M/s. KEMA test report referred above. This approval may be deemed to have been revoked with immediate effect at any time, if any of the conditions subject to which approval has been granted is violated or not complied with. The approval may also be amended or withdrawn at any time, if considered necessary in the interest of safety.

The field performance report from actual users /your customers of the subject equipment may please be collected and furnished to this office for verification and record at regular intervals.

This approval is otherwise valid a period of five years from the date of issue.

Yours faithfully,

(Dr. Yogesh khare)
Controller of Explosives
for Chief Controller of Explosives
Nagpur

Copy to :

1. The Jt. Chief Controller of Explosives, West Circle, Mumbai.
2. M/s. Endress hauser India Pvt. Ltd., Raj Plaza Wing A & B 5th Floor LBS Marg, Vikhroli West, Mumbai (Maharashtra)

for Chief Controller of Explosives