



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

FTC 260-Jbcde MINICAP. Capacitive Level Limit Switch.

DIP / II,III / 1 / EFG / T5 Ta = 80°C; Type 4X

b = Process connection; B (NPT 1 in.).

c = Electronic insert; 2 or 4.

d = Enclosure/conduit entry; B (F14 encl, NPT1/2), H (F34 encl, NPT 1/2).

e = Additional option; 1 (basic version), 3 (glass window, F34 only)

Equipment Ratings:

Dust-ignitionproof for use in Class II and III, Division 1, Groups E, F and G hazardous (classified) locations, indoor and outdoor (Type 4X).

FM Approved for:

Endress+Hauser GmbH+Co KG
Maulburg, Germany



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	2011
Class 3616	2011
Class 3810	2005
ANSI/NEMA 250	2008
ANSI/ISA-61010-1	2012

Original Project ID: 3001232

Approval Granted: November 5, 1998

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
3055541	June 22, 2015		

FM Approvals LLC

J.E. Marquedant

J.E. Marquedant
Manager of Electrical Systems

22 June 2015

Date