

Certificate of Compliance

Certificate: 1895815

Master Contract: 151079

Project: 1895815

Date Issued: July 24, 2007

Issued to: Endress + Hauser GmbH + Co. KG
P.O. Box 1261, Hauptstrasse 1
79690 Maulburg, BadenWuertenberg
GERMANY

*The products listed below are eligible to bear the CSA Mark shown
with adjacent indicators 'C' and 'US'*



Issued by: H.W. Zeller



Authorized by: M.H.J. Hoendervangers



PRODUCTS

CLASS 2252 05 - PROCESS CONTROL EQUIPMENT

CLASS 2252 85 - PROCESS CONTROL EQUIPMENT (Certified to U.S. Standards)

Gateway for Remote Monitoring of connected devices, permanently connected, Class II equipment, Pollution Degree 2, Installation Cat. II. rated as follows:

Model FXZ 520;

Rated: 85-253 V, 50-60 Hz, 8 VA max

Installation: in a suitable enclosure.

Certificate: 1895815

Project: 1895815



Master Contract: 151079

Date Issued: July 24, 2007

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 61010-1-04 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements

UL Std. No. 61010-1 (2nd Edition) - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements

Supplement to Certificate of Compliance

Certificate: 1895815

Master Contract: 151079

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
1895815	July 24, 2007	cCSAus original Certification of Gateway for Remote Monitoring of connected devices, model FXZ520