

Translation

3. SUPPLEMENT

to Certificate No. TÜV 01 ATEX 1685

Equipment: Waterpilot Typ FMX 167-...

Manufacturer: Endress+Hauser GmbH+Co. KG
Address: Hauptstraße 1
79689 Maulburg
Germany

Order number: 8000556150
Date of issue: 2010-11-26

Amendments:

In the future the Waterpilot type FMX 167-... may also be manufactured according to the documents listed in the test report. The modifications comprise the consideration of 60079-0:2009 and of EN 60079-11:2007. Furthermore modifications of the name plates and of the safety instructions were made. In the future a terminal box may be optionally used.

In the future the marking is:  II 2 G Ex ia IIC T6 Gb

The electrical data and all other data apply unchanged for this supplement.

According to this supplement the equipment meets the requirements of the following standards:

EN 60 079-0:2009 **EN 60 079-11:2007**

(16) The test documents are listed in the test report No. 10 203 556150.

(17) Special conditions for safe use


none

(18) Essential Health and Safety Requirements

no additional ones

TÜV NORD CERT GmbH, Langemarckstraße 20, 45141 Essen, accredited by the central office of the countries for safety engineering (ZLS), Ident. Nr. 0044, legal successor of the TÜV NORD CERT GmbH & Co. KG Ident. Nr. 0032

The head of the certification body



Schwedt

Hanover office, Am TÜV 1, 30519 Hannover, Tel.: +49 (0) 511 986-1455, Fax: +49 (0) 511 986-1590