



# Certificate of Compliance

Certificate Number: LR 53988-61

Revision:

Date Issued: November 14, 1995

Issued To: ENDRESS + HAUSER GMBH CO.  
HAUPTSTRASSE 1  
D-79689 Maulberg, Germany

Attention: Dr. Gerold Klotz-Engmann

*The products listed below are eligible to bear the CSA Mark.*

Issued By: E. Klier, P. Eng.  
Toronto, ON Canada

Signature

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

PRODUCTS

Class I, Div 1, Groups A, B, C, D;

Class II, Div 1, Groups E, F, G;

Class III:

FMT 131 Temperature Sensor Type 4X.



## Certificate of Compliance

Certificate Number: LR 53988-61

Revision:

Date Issued: November 14, 1995

---

### APPLICABLE REQUIREMENTS

CSA Std C22.2 No.	30-M1986	-	Explosion-Proof Enclosures for Use in Class I Hazardous Locations
CAN/CSA-C22.2 No.	94-M91	-	Special Purpose Enclosures
CSA Std C22.2 No.	142-M1987	-	Process Control Equipment

### MARKINGS

- Company Name
- Model number
- Serial number
- Electrical rating
- Hazardous Location designation
- Special purpose enclosure designation, "Type 4X"
- CSA Monogram
- Caution re conduit seal to be installed within 50mm of the enclosure.