



Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Endress + Hauser GmbH+Co. KG
Hauptstraße 1, D-79689 Maulburg

the Certificate No.: **Z00656** for the PROFIBUS Slave:

Product Name: Cerabar S PROFIBUS PA
Revision: HW: All, SW: All
GSD: PA039700.gsd
EH3X1501.gsd Rev. 0.5

This certificate confirms that the product has successfully passed the certification tests with the following scope:

| | | |
|-------------------------------------|---------|----------------------------|
| <input checked="" type="checkbox"/> | DP-V0 | MS0, Freeze, Set_Slave_Add |
| <input checked="" type="checkbox"/> | DP-V1 | MS2 |
| <input type="checkbox"/> | DP-V2 | |
| <input checked="" type="checkbox"/> | Profile | PA Devices V 3.0 |

Test Report Number: itm 633 PA 01/01
Authorized Test Laboratory: itm, München
Expiry date of Certificate: September 20, 2008

The tests were executed in accordance with the following documents:
"Prüfrichtlinie für Feldgeräte entsprechend "PROFIBUS PA Profile for Process Control Devices, Version 3.0", Version 3.1", April 2000, and
"Test Specifications for PROFIBUS DP Slaves, Version 2.3", March 2000.
This certificate is granted according to the document "Framework for testing and certification of PROFIBUS products".

Karlsruhe, October 18, 2005



(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.

(Edgar Küster)

(Prof. K. Bender)