



Manufacturer Information

for users regarding software updates
(following the NAMUR recommendation 53)

Fieldgate - FXA520 - all variants

1 Type of Product

- Field device / signal processing device
- Software application for display and monitoring / asset management / handheld terminal etc.
- Modem / interface

Manufacturer : Endress+Hauser Process Solutions AG
 Product : Fieldgate FXA520
 Type and order code : - all variants -

2 Software

Previous software version : 1.05.02
 New software version : 1.05.03
 How can the previous software version number be identified? : Check Info page of device with web browser
 Description of the modification in comparison with the predecessor version : - Bug fixed in email processing: Further recipients got incomplete or even empty emails

3 Compatibility

Is the new product software compatible with the previous version, installed device driver components and operating tools?

- Yes
- No, reason:

Is a software update generally recommended?

- Yes, reason:

- No, reason:

only relevant, if emailing to further recipients shall be used



Level



Pressure



Flow



Temperature



Liquid
Analysis



Registration



Systems
Components



Services



Solutions

Manufacturer Information

for users regarding software updates
(following the NAMUR recommendation 53)

4 Instruction manual

Is a new instruction manual necessary due to the software modification?

Yes

No

The manual that corresponds to the new software version is:

Product	Communication options	Manual type	Document identifier
---------	-----------------------	-------------	---------------------

The new instruction manuals can be downloaded from the Internet:

<http://www.endress.com>

- area „DOWNLOAD“

- declaration of the device and kind of manual